

# SEMINOLE TRIBE OF FLORIDA

Purchasing Department  
 6300 STIRLING ROAD  
 HOLLYWOOD, FLORIDA 33024  
 PHONE: (954) 966-6300  
 FAX: (954) 967-3478  
<http://www.seminoletribe.com>



Tribal Officers:

MARCELLUS W. OSCEOLA, JR.  
 Chairman

HOLLY TIGER  
 Vice-Chairwoman

LAVONNE ROSE  
 Secretary

PETER HAHN  
 Treasurer

## RFP 06-2024 TRIBALWIDE STREET LIGHTING AND MAINTENANCE SERVICES

### Addendum No. 4, Date issued March 27, 2024

This **Addendum No. 4** is hereby made a part of **RFP 06-2024** and has been issued by the Seminole Tribe of Florida (hereinafter the “Tribe”) to answer questions submitted by prospective bidders and extend the Proposal Due Date.

**RFP 06-2024** is amended as follows:

**1. Addressing Submitted Questions:**

The following questions are being addressed through this **Addendum No. 4**:

GENERAL	
1.	<p><b>Q:</b> When trying to complete “Miscellaneous” in <i>Exhibit A – Proposal Form REV001</i> it is hard to quote one price for six (6) reservations. Can BIDDER submit individual pricing for each reservation so that BIDDER can provide the TRIBE with the best possible price? If BIDDER can only quote one price for all reservations can BIDDER pick the farthest reservation from BIDDER’s location/proximity to service area and use that price for all reservations as this would not be fair to the TRIBE as the cost will be much less to closer reservations.</p> <p><b>A:</b> Please refer to the revised <i>Exhibit A - Proposal Form REV002</i> provided through this <b>Addendum No. 4</b>. The bidder can use one multiplier for the work located at each reservation. Use “1” for baseline (no multiplier), or a multiplier greater than “1” for multiplier premium.</p>
2.	<p><b>Q:</b> Is the Tampa reservation the Lakeland reservation only?</p> <p><b>A:</b> Tampa and Lakeland are two (2) different reservations.</p>

3.	<u>Q:</u> For the Hollywood reservation, does it not include anything outside of the Hollywood reservation?
	<u>A:</u> Only the lights inside the boundary of the reservation are included in the maintenance agreement.
4.	<u>Q:</u> What is the pole height and pole requirements for item eleven (11)?
	<u>A:</u> The service pole height is twelve feet (12'), and it is Type P-IIA. FDOT (2024-25) index 641-010 (2 of 11).
5.	<u>Q:</u> Is single post sign illuminated or not for item twelve (12)?
	<u>A:</u> No. These are standard static signs.
6.	<u>Q:</u> Is single post sign illuminated or not for item thirteen (13)?
	<u>A:</u> No. These are standard static signs.
7.	<u>Q:</u> What is the wiring size and length of conductors to be disposed for item seventeen (17)?
	<u>A:</u> There is no wiring size since it is a removal item. Assume a wire size of #4 AWG for estimating purposes. The length and quantities are based on linear feet and to be computed by the Contractor based on the specific project.
8.	<u>Q:</u> Please provide cut sheet for item nineteen (19).
	<u>A:</u> There is no cut sheet for luminaire and bracket arm removal. Assume worst case twelve foot (12') bracket arm and cobra luminaire removal on standard FDOT style aluminum pole.
9.	<u>Q:</u> What is the type of light pole foundation for item twenty (20)?
	<u>A:</u> Assume a standard FDOT light pole foundation with a maximum depth of eight feet (8') per FDOT (2024-25) index 715-002 (4 of 9).
10.	<u>Q:</u> What are the specifications of the Cobra head for item twenty-one (21)?
	<u>A:</u> Use the specifications from the manufacturer. Assume replacing an existing HPS Cobra Head luminaire (Conventional) with an LED luminaire from the FDOT Approved Products List, such as Autobahn, Evolve, etc.
11.	<u>Q:</u> What are the specifications of ballast, wattage, and type (light-emitting diode (LED), high-intensity discharge (HID), fluorescent) for item twenty-two (22)?
	<u>A:</u> The specifications for the luminaires in the reservation vary. Please assume the worst-case scenario to estimate the unit cost and provide description of item selected.

12.	<u>Q:</u> What types of retrofit (light-emitting diode (LED), high-intensity discharge (HID), florescent) for item twenty-three (23)?
	<u>A:</u> The specifications for the luminaires in the reservation vary. Please assume the worst-case scenario to estimate the unit cost and provide description of item selected.
13.	<u>Q:</u> Does the TRIBE wants labor included or is that supposed to be included in Miscellaneous for item twenty-four (24)?
	<u>A:</u> All items including item twenty-four (24) should include the cost of labor, unless otherwise is specified.
14.	<u>Q:</u> Should item twenty-five (25) be an hourly rate? Please refer to item fifty (50).
	<u>A:</u> Please refer to the revised <i>Exhibit A - Proposal Form REV002</i> provided through this <b>Addendum No. 4</b> . Item twenty-five (25) has been revised to be hourly to match fifty (50).
15.	<u>Q:</u> What is frangible base for item twenty-six (26)? Please provide cut sheet.
	<u>A:</u> There is no cut sheet. Follow and use the standard FDOT frangible base from FDOT Standard Plans (FY 2024-25), Index 715-002 (4 of 9, 1 of 9)
16.	<u>Q:</u> Please provide cut sheet for item twenty-seven (27).
	<u>A:</u> A copy of the cut sheet for the standard light pole contained within the lighting report and lighting plans will be provided to the selected Contractor. For reference, use Catalog number: LUMINAIRE CATALOG ORDERING NO. ATB0_P302_ R2_3K_NL. (HAPCO ALUMINUM POLE.)
17.	<u>Q:</u> Please provide cut sheet for item twenty-eight (28).
	<u>A:</u> A copy of the cut sheet for the standard light pole contained within the lighting report and lighting plans will be provided to the selected contractor. This is a standard FDOT aluminum cobra head light pole with LED luminaire such as Lumec (Road Focus) type. For reference, use Catalog number: RFL, 241W112LED, CCT 3k, G2, R3M, HVU, DMG, PH9-RCD7-SP2- GY3
18.	<u>Q:</u> What is the distance of the light pole to be relocated for item twenty-nine (29)? Please provide cut sheet
	<u>A:</u> There is no specific distance for relocation of light pole. For estimating purposes, assume a maximum distance of twenty feet (20'). There is no cut sheet or plan sheet.
19.	<u>Q:</u> Please provide cut sheet for item thirty (30).
	<u>A:</u> There is no cut sheet or plan sheet. Assume a maximum light pole depth of eight feet (8') per FDOT Standard Plans (FY 2024-25), Index 715-002 (4 of 9).

20.	<p><u>Q:</u> Please provide cut sheet for item thirty-one (31).</p> <p><u>A:</u> No cut sheet. Follow and use the standard FDOT PCDS from FDOT Standard Plans (FY 2024-25), Index 715-001 (1 of 3).</p>
21.	<p><u>Q:</u> Please provide cut sheet for item thirty-two (32).</p> <p><u>A:</u> A copy of the cut sheet for the decorative light pole contained within the lighting report and lighting plans will be provided to the selected contractor. For reference, use: 83 WATT LED 3000K, AUTOBAHN SERIES ATB0 (P302 R2 3K, MVOLT, 120-277V). MOUNTING HEIGHT OF 35' AND 12' ARM (HAPCO ALUMINUM POLE). LAMP SHALL PRODUCE 11,789 LUMENS, WIRED FOR 240 V. SHALL BE GALVANIZED FINISH (GRAY COLOR). LUMINAIRE CATALOG ORDERING NO. ATB0_P302_R2_3K_NL.</p>
22.	<p><u>Q:</u> Please provide cut sheet for item thirty-four (34), item will be based on the type of box the hand hole cover is for.</p> <p><u>A:</u> No cut sheet. Use FDOT standard PULL &amp; SPLICE BOX, F&amp;I, 13" x 24" COVER SIZE.</p>
23.	<p><u>Q:</u> What is the amperage, indoors or outdoors, is it single or three (3) phases, and what is voltage rate for item thirty-six (36)?</p> <p><u>A:</u> Assume for purposes of estimating a 120/240 Volt, 1 phase, 3-wire service. It will be all outdoors. Assume 200 AMP main breaker.</p>
24.	<p><u>Q:</u> What is the amperage for item thirty-seven (37)? Please provide cut sheet.</p> <p><u>A:</u> No cut sheet. Assume 200 AMPS.</p>
25.	<p><u>Q:</u> What is the amperage, single or three (3) phases for item thirty-eight (38)? Please provide cut sheet.</p> <p><u>A:</u> No cut sheet. Assume 200 AMPS.</p>
26.	<p><u>Q:</u> What is the amperage, voltage, is it single or three (3) phases for item thirty-nine (39)? Please provide cut sheet.</p> <p><u>A:</u> Assume for purposes of estimating a 120/240 Volt, 1 phase, 3-wire service. It will be all outdoors. Assume 200 AMP.</p>
27.	<p><u>Q:</u> What is the amperage for item forty (40)? Please provide cut sheet.</p> <p><u>A:</u> Match the existing fuse. For purposes of this estimate assume a 30 AMP fuse. No cut sheet available.</p>

28.	<b>Q:</b> What is the amperage, voltage, and is it single or three (3) phases for item forty-one (41)? Please provide cut sheet.
	<b>A:</b> Fuse holder. 30Amp, 600 Vac/dc. For purposes of estimating use single phase. Fuses – 250 Vac/125 Vdc. 2 AMP rating, AC voltage rating 250.
29.	<b>Q:</b> What is a dummy slug? Please provide cut sheet for item forty-two (42).
	<b>A:</b> Item deleted.
30.	<b>Q:</b> What is the amperage, rating, and is it single or three (3) phases for item forty-three (43)? Please provide cut sheet.
	<b>A:</b> 200 Amp, 1 phase. No Cut sheets.
31.	<b>Q:</b> What is the load center part number for item forty-four (44)? Please provide cut sheet.
	<b>A:</b> No cut sheet. Provide estimate for a ground mount cabinet cover plate.
32.	<b>Q:</b> Please provide cut sheet for item forty-five (45).
	<b>A:</b> Item deleted.

**2. Extension of Proposal Due Date:**

To allow additional time for prospective bidders to review the answers provided by the Tribe, the following date(s) has been revised:

The new **Proposal Due Date** is Friday, April 5, 2024 @ 3:00 PM (ET).

All other content for **RFP 06-2024** remains the same.

**END OF ADDENDUM NO. 4**